



ITEM	PART #	MATERIAL	QTY
1	9187	4T, 200A Meter Base, No Breaker	1
2		Form 2S, CL200, 240V 1Ø Meter	1
3	3110	Conductor, #10 CU Stranded, THHN, Black	6
4	3111	Conductor, #10 CU Stranded, THHN, White	6
5	8040-2	Conduit, RMC, 2"	4
6	8220-2	Weatherhead, 2"	1
7		Lag, Screw (As Required)	2
8	9027	#6, CU Crimp	1
9	3011	Conductor, #6 CU Stranded, UV Jkt, Green	2
10	9160-2	Strap, Conduit 2"	1

ITEM	PART #	MATERIAL	QTY
11	9495	Clamp, Burndy YPC26R8U	2

Notes:

1. 120/240V Single-Phase locations only
2. Wired 120Vl-g to energize A-phase stator of the meter, which energizes the Itron NIC within the Meter.
3. Item 11 to be covered with Scotch 88 electrical tape.
4. A minimum of 13" must be maintained from the top of the meter to any supply lines or equipment.
5. Meter box to visibly tagged with "AMI2.2".

AMI Meter Antenna

07/15/22

REV0



AMI2.2