



A	B	C	D	1	A	B	C	D	
ITEM	PART #	MATERIAL	QTY	1	ITEM	PART #	MATERIAL	QTY	
2	a	4310	Insulator, Pin Type	4	15	aw	9100	Washer, Spring	8
3	a2	4311	Insulator, Clamp Type	2	16	cm	9471	Insulator, Spool	1
4	c	9371	Bolt, Machine - 1/2"	4	17	cu	2040	Brace, Wood 84" X 24"	4
5	c2	9372	Bolt, Machine - 5/8"	2	18	da	2155	Clevis, Rigid	1
6	d	9098	Washer, Round 1/2"	4	19	ek	9094	Locknut, 1/2"	4
7	d2	9091	Washer, Square - 2" X 2"	2	20	ek	9096	Locknut, 5/8"	12
8	d3	9091-3-5/8	Washer, Square - 3" 11/16"	16	21	ek	9096	Locknut, 3/4"	2
9	d4	9092	Washer, Curved - 3" 11/16"	1	22	rp	4715	Salisbury Coverup	8'
10	d5	9091-4	Washer, Square - 4" 13/16"	2	23	rp1	4766	Perch Guard, 36"	2
11	f	4375	Pin, Crossarm Saddle	6	24	rp2	4764	Perch Guard, 24"	2
12	g	4090	Crossarm, 10' Tangent	2	25	rp5	4780	Zena Spikes - 30"	2
13	n	9363	Bolt, Double Arming, 5/8" Req'd Length	5	26	rp7	4769	Perch Guard, Extension	6
14	n	9364	Bolt, Double Arming, 3/4" Req'd Length	1	27	rp8	4743	Perch Guard, Pole Cap	1

Design Parameters:

1. See Table V of RUS Bulletin 1728F-803

Notes:

1. Center phase and/or neutral may be located on opposite side of the pole where necessary to avoid crossing of wires in midspan.

**24.9/14.4KV,
3-PHASE DOUBLE PRIMARY SUPPORT,
CROSSARM CONSTRUCTION
LARGE CONDUCTORS**

RUS		VC2.52LRG
11/7/17		
REV. B		

A Touchstone Energy® Cooperative 