


NOTES:

1. Ground wire to be located on same side as neutral conductor and in quadrant opposite climbing space or pole top pin.
2. Staples on ground wire shall be 6" apart.
3. Copper ground wire ("cj") to have a minimum conductivity of No. 6 Copper or equivalent; use copper ground plate.
4. Use copper plated ground rod, copper ground wire and staples, OR, use galvanized steel ground rod, staples and aluminum ground wire

ITEM	QTY	MATERIAL	ITEM	QTY	MATERIAL
ai	1	Ground Rod	cj		Wire, pole ground
aj	1	Clamp, ground rod	p	1	Connector, compression
al		Staple, ground wire, as req'd			

NOTES: DESIGN PARAMETERS:

**POLE PROTECTION ASSEMBLY
GROUND ROD TYPE**

03/07/12		H1.1A
Rev. 0		

A Touchstone Energy® Cooperative