



1. All clearances and protective devices to be in conformance to the most stringent requirements of either the NESC, NEC or other codes of governmental or regulating authorities as applicable.
2. If length of conduit exceeds 10 feet, coupling is permitted on end adjacent to meter.
3. Guy pole as required.
4. Meter loop assemblies are available from 10' to 35' in increments of 5'. Match assembly length to meter pole call-out.

MATERIALS LISTING

ITEM	DESCRIPTION	QTY	UNIT	PREC #
1	200A Single-Phase Meter Loop	1	Ea.	8310-*
2	#6 THHN Copper Ground Wire	As Required		
3	7T 200A 3 Phase Meter Box w/Disconnect	1	Ea.	9186
4	Form 16S/15S Class 200 120-480V 4-Wire 3Ø Meter	1	Ea.	

Design Parameters: > See design notes above. > *Add required loop length. > 86.6% combined total load allowed from 25kVA bank for 180A full load current.	120/240V 200A Open Delta Self Contained Service 4-Wire Down Loop Mounted on Transformer Pole (10kVA+15kVA Xfms.)		
	5/12/2008 Rev. 0		Q2.1-02PSC*