


MATERIALS LISTING

ITEM	DESCRIPTION	QTY	UNIT	PREC #
ge	2" Adapter	1	Ea.	9801-2
Ugc	2" Conduit	as Required	Ft.	8245-2
gd	2" Straps	1	Ea.	9160-2
gf	Bushing	1	Ea.	9803-2
gr	Lock Ring	2	Ea.	9804-2
gb	(4T 200A Meter Box with 200A breaker)	1	Ea.	9182
ga	(Form 2S Class 200 240V 3-Wire 1Ø Meter)	1	Ea.	

Design Parameters: > See design notes above. > 4/0 USE-2 Cu or 4/0 URD Al Triplex secondary cabling recommended. > Expansion Joints required on conduit.	Underground to Meter on Building 120/240V, 100A 15kVA Max. (200A 25kVA Max.) 3-Wire Installation		UM8-02SC
	4/17/2009		
	Rev. A		