

ITEM	MATERIAL	QTY	ITEM	MATERIAL	QTY
av	Jumpers, as req'd	4	o	Bolt, eye, 5/8" x req'd length	4
d	Washer, square, 3", curved	4	p	Connectors	as req'd
ek	Locknuts	4	rp8	Perch Guard Pole Top Cone	1
k	Insulator, Epoxilator	2			

**NOTES:**

1. Separate 6" (top position only) when angle equals 90°.
2. When additional guys are required, install guys 6" below deadend assemblies and use two VA5.4's or install 12" guy strain insulators ("w") at top of uppermost guys.


DESIGN PARAMETERS:  
ALLOWABLE LONGITUDINAL  
LOAD = 5000 lbs./Conductor

24.9/14.4kV, 1-Phase Primary  
Deadend Angle (90 - 150 )

RUS

04/06/2009

Rev. B



VA4.1RG