



ITEM	PART #	MATERIAL	QTY	ITEM	PART #	MATERIAL	QTY
a	4310	Insulator, Pin Type	4	n	9363	Bolt, Double Arming, 5/8"	5
a2	4311	Insulator, Clamp Type	2	n2	9364	Bolt, Double Arming, 3/4"	1
c	9371	Bolt, Machine - 1/2"	4	aw	9100	Washer, Spring	8
c2	9372	Bolt, Machine - 5/8"	2	cm	9471	Insulator, Spool	1
d	9098	Washer, Round 1/2"	4	cu	2040	Brace, Wood 84" X 24"	4
d2	9091	Washer, Square - 2" X 2"	2	da	2155	Clevis, Rigid	1
d3	9091-3-5/8	Washer, Square - 3" 11//16"	16	ek	9094	Locknut, 1/2"	4
d4	9092	Washer, Curved - 3" 11//16"	1	ek	9096	Locknut, 5/8"	12
d5	9091-4	Washer, Square - 4" 13/16	2	ek	9096	Locknut, 3/4"	2
f	4375	Pin, Crossarm Saddle	6	rp	4715	Salisbury Coverup	8'
g	4090	Crossarm, 10' Tangent	2				

Design Parameters:

See Table V of RUS Bulletin 1728F-803

Notes:

- Center phase and/or neutral may be located on opposite side of the pole where necessary to avoid crossing of wires in midspan.

**24.9/14.4KV,
3-PHASE DOUBLE PRIMARY SUPPORT,
CROSSARM CONSTRUCTION
LARGE CONDUCTORS**

RUS
11/7/17
REV. A



VC2.52LR