



ITEM	MATERIAL	Qty	ITEM	MATERIAL	Qty
a1	Insulator, clamp top	1	eu	Link, extension fiberglass	3
k	Epoxillator, polymer distribution deadend	3	av	Jumpers, insulated	30'
p	Connectors, as req'd				

**NOTES:**

1. Retrofit standard for avian protection for 8' crossarm to be used on all horizontal tap configurations.
2. Insulator/pin is to be replaced with clamp type insulator

**24.9 / 14.4 KV, 3-PHASE TAKEOFF ARM  
AVIAN SAFETY RETROFIT**

RUS

09/21/10

Rev. 0



**VC5TMA-1**