



ITEM	MATERIAL	QTY	ITEM	MATERIAL	QTY
p	Connectors, As Req'd		rp2	Perch Guard 24"	1
av	Jumper, Insulated	30'	rp11	Arrester Cap	2
ax	Cutout Arrester Combo	2	rp12	Cutout Cap	2
rp1	Perch Guard 36"	2	rp13	Transformer Bushing Cap	2

NOTES:

1. Bushing Cover shall be installed over the first skirt of transformer bushing.
2. Retrofit standard for avian and grouse protection for 8 ft. cross arms.
3. Retire individual arresters and cutouts on this assembly and replace with cutout arrester combo.

**24.9 / 14.4 KV,
TWO-PHASE TRANSFORMER BANK
AVIAN/GROUSE RETROFIT**

RUS
05/31/13
Rev. A



VG2MAG-1