



ITEM	MATERIAL	QTY
p	Connectors, As Req'd	
av	Jumper, Insulated	30'
rp1	Perch Guard, 36"	4
rp2	Perch Guard, 24"	2

ITEM	MATERIAL	QTY
rp11	Arrester Cap	3
rp12	Cutout Cap	3
rp13	Transformer Bushing Cap	3

NOTES:

1. Bushing Cover shall be installed over the first skirt of transformer bushing.
2. Retrofit standard for avian and grouse protection for double 8 ft. cross arms.

24.9/14.4kV, 3-PHASE TRANSFORMER BANK, AVIAN/GROUSE RETROFIT WITHOUT CUTOUTS

RUS

05/31/13

Rev. A



VG3MA-4
VG3MAG-4