



ITEM	MATERIAL	QTY	ITEM	MATERIAL	QTY
a	Insulator, (24.9/14.4 KV)	8	da	Insulator, spool -4"	1
a1	Insulator, clamp type, (24.9/14.4 KV)	4	d2	Washer, Square 2" x 2" x11/16"	30
bi	Gain Plate	1	d3	Washer, Square 3" x 3" x11/16" curved	1
c2	Bolt, machine, 5/8" x req'd length	2	ek	Locknuts	30
c1	Bolt, machine, 1/2" x 6"	8	f	Pins, crossarm saddle	12
cp	Salisbury coverup	16'	g1	Wood Crossarm, 3 5/8"x4 5/8"x8'-0"	2
cu	Brace, Wood 36"	4	g2	Wood Crossarm, 3 5/8"x4 5/8"x10'-0"	2
cu	Brace, Wood 60" span	4	n	Bolt, 5/8" DA	10
d1	Washer, round, 1/2"	8	s	clevis, rigid	1
aw	5/8" double coil lock washer	12			

NOTES:

- DESIGN PARAMETERS:  
(Table 5 up to 21° for 336)
- POLE SHOWN-40-4
- SALISBURY COVER UP TO EXTEND 3'  
BEYOND EACH CROSSARM.

DOUBLE SUPPORT ON CROSSARMS  
(TANGENT) ( LARGE CONDUCTORS)  
DOUBLE CIRCUIT PRIMARY  
24.9/14.4 kV

06/09/11

Rev. B



VD2.91LR