



ITEM	MATERIAL	QTY
af	Cutout Combo, dist. open (27 kv)	3
rp	Bushing caps	6
rp1	Perch guard 36"	4
rp5	Zena Spikes	2

ITEM	MATERIAL	QTY
rp	Arrestor cap	3
av	Jumpers, service, as req'd, insulated	40'
p	connectors, as req'd	

- NOTES:
1. Bushing cover on transformer is to be installed on first skirt only.
 2. Retrofit standard for avian and grouse protection for (2) 8' crossarms.
 3. Retire individual arrestor and cutouts on this assembly and replace with cutout combo.

24.9 / 14.4 KV, 3-PHASE TRANSFORMER BANK
AVIAN/GROUSE RETROFIT

RUS
06/16/11
Rev. 0



VG3MAG-3