



ITEM	MATERIAL	QTY	ITEM	MATERIAL	QTY
rp	Cut-out Cover	3	rp	Arrestor cap	3
rp	Bushing caps	6	av	Jumpers, service, as req'd, insulated	40'
rp2	Perch guard 24"	2	p	connectors, as req'd	
rp5	Zena Spikes	1			

- NOTES:
1. Bushing cover on transformer is to be installed on first skirt only.
  2. Retrofit standard for avian and grouse protection for 8' crossarms.

24.9 / 14.4 KV, 3-PHASE TRANSFORMER BANK  
 AVIAN/GROUSE RETROFIT WITHOUT CUT-OUTS

RUS

04/27/11

Rev. 0



VG3MA-2  
 VG3MAG-2