


ITEM	MATERIAL	QTY	ITEM	MATERIAL	QTY
a	Insulator, pin type	6	n	bolt, double arming, 5/8" x req'd length	4
b	Pin, pole top, offset	2	aw	Washer, spring	4
c1	Bolt, machine 1/2" x req'd length	4	da	Clevis, rigid	1
c2	Bolt, machine 5/8" x req'd length	4	cm	Insulator, spool - 3"	1
d1	Washer, round 1/2"	4	cu	Brace, wood, 36"	4
d2	Washer, square 2" x 2" x 11/16"	12	ek	Locknuts	16
d3	Washer, curved 3" x 3" x 11/16"	1	rp1	Perch Guard 36"	4
f	Pin, crossarm, steel,	6	rp6	Perch Guard Pole Top	2
g	Crossarm, 3 5/8" x 4 5/8" x 10'-0"	2	rp7	Perch Guard Extenders	4
rp5	Perch Guard 30"	2			

NOTES:

- Design Parameters & Tension Design Notes See Table II
- Coverup to extend 3' beyond the Crossarm

24.9 / 14.4 KV, 3-PHASE
DOUBLE PRIMARY SUPPORT, CROSSARM CONST.
SMALL CONDUCTORS

RUS		<h1 style="margin: 0;">VC2.21RG</h1>
01/20/12		
Rev. A		

A Touchstone Energy® Cooperative 