



ITEM	MATERIAL	QTY	ITEM	MATERIAL	QTY
a	Insulator, clamp top	4	a	Insulator, pin type	2
c1	Bolt, machine, 1/2" x req'd. length	4	aw	Washer, spring, 5/8"	8
c2	Bolt, machine, 5/8" x req'd. length	3	cm	Insulator, spool - 3"	2
d1	Washer, round - 1/2"	4	cu	Brace, crossarm, wood, 44"	4
d2	Washer, square, 2" x 2" x 11/16"	22	da	Clevis, rigid	2
f	Pin, crossarm, steel, clamp type	6	ek	Locknuts	18
g	Crossarm, 3 5/8" x 4 5/8" x 10'-0"	2	rp	Salisbury coverup	16'
n	Bolt, Double-arming, 5/8"	6			

NOTES:

- Design Parameters & Tension Design Notes See Table V
- Coverup to extend 3' beyond the Crossarm

24.9 / 14.4 KV, 3-PHASE
DOUBLE SUPPORT, NEUTRAL ON CROSSARMS
LARGE CONDUCTORS

RUS

02/10/12

Rev. A



VC2.51LR