



| ITEM | MATERIAL | QTY | ITEM | MATERIAL | QTY |
|------|---------------------------------|-----|------|--------------------|-----|
| p | Connector, as req'd | | rp | Arrester Cap Cover | 3 |
| av | Jumper, Service | 30' | rp1 | Perch Guard 36" | 2 |
| rp | Small Transformer Bushing Cover | 3 | rp2 | Perch Guard 24" | 1 |
| rp | Fusible Switch Cap Cover | 3 | | | |

NOTES:

1. Bushing Cover on transformer is to be installed on first skirt only.
2. Retrofit Standard for avian and grouse protection for 8ft crossarm.
3. Call out additional transformer bushing covers as needed.

24.9/14.4KV, 3-PHASE TRANSFORMER BANK
AVAIN/GROUSE RETROFIT WITHOUT CUT-OUTS

RUS

5/29/13

Rev. A



VG3MA-2
VG3MAG-2