


ITEM	MATERIAL	QTY	ITEM	MATERIAL	QTY
af	Cutout Combo, dist. open (27 kV)	3	rp	Arrestor cap	3
rp	Bushing caps	6	av	Jumpers, service, as req'd, insulated	40'
rp1	Perch guard 36"	4	p	connectors, as req'd	
rp5	Zena Spikes	2			

NOTES:

1. Bushing cover on transformer is to be installed on first skirt only.
2. Retrofit standard for avian and grouse protection for (2) 8' crossarms.
3. Retire individual arrestor and cutouts on this assembly and replace with cutout combo.

**24.9 / 14.4 KV, 3-PHASE TRANSFORMER BANK  
AVIAN/GROUSE RETROFIT**

RUS		<b>VG3MAG-3</b>
06/16/11		
Rev. 0		