



			VR1.03-	40	100	200
ITEM	PART #	MATERIAL	QTY	QTY	QTY	QTY
p		Connector, As Req'd				
ap	2140	Clamp, Hotline	1	1	1	1
ap1	2147	Stirrup, Hotline	1	1	1	1
av	3114	Wire, Insulated Tap - #2 AWG Cu	10'	10'	10'	10'
be	640040-01	Recloser, Cutout Mount - 40 Amp	1			
be	640100-01	Recloser, Cutout Mount - 100 Amp		1		
be	640200-01	Recloser, Cutout Mount - 200 Amp				1
rp	4725	Cover, Cutout	1	1	1	1

**NOTE**

1. Mount cutouts so Recloser faces the climbing face of pole.
2. Where source wire is 336.4 ACSR (18/1)), replace item ap1 with part no. 2148 - Hot Line Stirrup 336.

**Vacuum Interrupter Recloser  
(CUTOUT MOUNT)  
1-PHASE PRIMARY 24.9/14.4kV**

RUS  
1/27/2025  
REV. 0



**VR1.03**